



# Certificate of Conformity

Certificate Number: CN-PV-230680

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Huizhou Epever Technology Co., Ltd. No.103, Dongxing Rd,Chenjiang Street, Zhongkai High-Tech Zone, Huizhou, China
<b>Product:</b>	PV Hybrid inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	EP-HY-3.6-G3, EP-HY-5.0-G3
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	EN 50549-1: 2019 Requirements for generating plants to be connected in parallel with distribution networks Part 1: Connection to a LV distribution network - Generating plants up to and including Type B Type approval for Type B
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	231011062GZU-003, 24 November 2023

According to Annex H of the standard EN 50549-1:2019, generating plants compliant with the clauses of this European Standard are considered to be compliant with the relevant Article of COMMISSION REGULATION (EU) 2016/631, provided, that all settings as provided by the DSO and the responsible party are complied with. Additional information in Appendix.



Signature

**Certification Manager: Grady Ye**  
**Date: 01 December 2023**



PRD N° 306B

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230680

Model	EP-HY-3.6-G3	EP-HY-5.0-G3
Input Data (PV)		
Max. PV array open-circuit Voltage	600Vd.c	
Max. total PV array short-circuit circuit	2*20Ad.c	
Max. operating PV input current	2*15Ad.c	
PV input operating voltage range	100~600Vd.c	
MPPT input operating voltage range	120~550Vd.c	
Number of independent MPP input	2	
Output Data (AC)		
Nominal AC output Power	3600W	5000W
AC nominal voltage	230Va.c	
AC grid frequency	50Hz	
Max. output current	16Aa.c	22.8Aa.c
Power factor (Full load)	>0.99	
Backup terminal parameter (AC)		
Nominal AC output Power	3600W	
AC nominal voltage	230Va.c	
AC grid frequency	50Hz	
Max. output current	16Aa.c	
Battery		
Battery Type	Lead-acid or Li-ion	
Normal voltage	48V	
Operating voltage range	46.7~57.6V	
Max. charging current	65Ad.c	
Max. discharging current	81Ad.c	
Max. charging Power	3600W	
Max. discharging Power	3600W	
General Data		
IP Degree	IP65	
Protect class	I	
Operation temp.	-25°C to +60°C	
Software version	SB1.0	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230680

Interface protection settings according to EN 50549-1:2019			
Parameter	Max. disconnection time	Min. operate time	Trip value
Undervoltage threshold stage 1 [27 < ]	100s	0.1s (0.1 s steps)	Trip value Config. from 0.2 to 1 Un (0.01 Un steps)
Undervoltage threshold stage 2 [27 << ]	5s	0.1s (0.05 s steps)	Trip value Config. from 0.2 to 1 Un (0.01 Un steps)
Overvoltage threshold stage 1 [59 > ]	100s	0.1s (0.1 s steps)	Trip value Config. from 1.0 to 1.2 Un (0.01 Un steps)
Overvoltage threshold stage 2 [59 >> ]	5s	0.1s (0.05 s steps)	Trip value Config. from 1.0 to 1.3 Un (0.01 Un steps)
Overvoltage 10 min mean protection	Trip time Config ≤ 3s not adjustable Time delay setting = 0 ms		Trip value Config. from 1.0 to 1.15Un (0.01 Un steps)
Underfrequency threshold stage 1 [81 < ]	100s	0.1s (0.1s steps)	Trip value Config. from 47.0 to 50.0Hz (0.1Hz steps)
Underfrequency threshold stage 2 [81 << ]	5s	0.1s (0.05 s steps)	Trip value Config. from 47.0 to 50.0Hz (0.1Hz steps)
Overfrequency threshold stage 1 [81 > ]	100s	0.1s (0.1s steps)	Trip value Config. from 50.0 to 52.0Hz (0.1Hz steps)
Overfrequency threshold stage 2 [81 >> ]	5s	0.1s (0.05 s steps)	Trip value Config. from 50.0 to 52.0Hz (0.1Hz steps)
Starting to and reconnection settings for voltage	50%-120% adjustable, 85%Un ≤ U ≤ 1.10Un default		
Starting to generate electrical power	47Hz – 52Hz adjustable, 49.5Hz ≤ U ≤ 50.1Hz default		
Reconnection settings for frequency	47Hz – 52Hz adjustable, 49.5Hz ≤ U ≤ 50.2Hz default		
Observation time	10s-60s adjustable, 60s default		
Active power increase gradient	6%-3000%/min adjustable, 10%/min default		
Permanent DC injection	0.5% of rated inverter output		
Loss of mains according to EN 62116	Within 2s		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.